



ARPIAN Consulting Engineers

702.05

2' x 3' DROP INLET

SCALE: 1" = 2' REV. 6-19-00

- NOTES:
1. USE EITHER CONC. BUILDING BRICK-ASTM C55, GRADE N, TYPE 1 OR CLAY BRICK-ASTM C32, GRADE MS.
 2. MORTAR TO BE TYPE M.
 3. CONCRETE PIPE TO BE CLASS III
 4. ALL DROP INLETS OVER 3'-6" IN DEPTH SHALL BE PROVIDED WITH STEPS.(1'-2" O.C.)
 5. PRECAST BOXES TO CONFORM TO LATEST ASTM C-913
 6. PRECAST BOXES CONCRETE STRENGTH TO BE A MINIMUM 4,000 PSI AT 28 DAYS