



APPLIAN Consulting Engineers

# 703.07

## 2' x 3' DROP INLET

### with 3' x VARIABLE WIDTH BOX

SCALE: 1" = 2'

REV. 5-15-00

**NOTES:**

1. USE EITHER CONC. BUILDING BRICK-ASTM C55, GRADE N, TYPE 1 OR CLAY BRICK-ASTM C32, GRADE MS.
2. MORTAR TO BE TYPE M.
3. CONCRETE PIPE TO BE CLASS III
4. ALL BOXES OVER 3'-6" IN DEPTH SHALL BE PROVIDED WITH STEPS. (12" O.C.)