



APPIAN Consulting Engineers

703.13

2' x 3' DROP INLET at TURN DOWN CURB

SCALE: 1" = 2'

REV. 6-16-00

NOTES:

1. USE EITHER CONC. BUILDING BRICK-ASTM C55, GRADE N, TYPE 1 OR CLAY BRICK-ASTM C32, GRADE MS.
2. MORTAR TO BE TYPE M.
3. CONCRETE PIPE TO BE CLASS III
4. ALL DROP INLETS OVER 3'-6" IN DEPTH SHALL BE PROVIDED WITH STEPS.(1'-2" O.C.)
5. PRECAST BOXES TO CONFORM TO LATEST ASTM C-913
6. PRECAST BOXES CONCRETE STRENGTH TO BE A MINIMUM 4,000 PSI AT 28 DAYS